COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98041
Permit No.
Basin 105

NOTICE OF INTENT NO. 52331

1. OWNER DOUG COLEMAN
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1889 ARABIAN ~~CT~~ LN
GARDNERVILLE, NV 89410

2. LOCATION ~~SW~~ ¼ ~~NE~~ ¼ Sec 24 T 12 N R 20 E DOUGLAS County
PERMIT NO. NE SW (Issued by Water Resources) | 1220-24-302-041 (Parcel No.) | RHUENSTROTH SUBDIVISION (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	5	5
COURSE SANDS AND BROWN CLAY		5	16	9
COURSE GRAVELS		16	21	5
BROWN CLAY		21	26	5
LARGE GRAVELS		26	119	93
COURSE GRAVELS VOLCANIC SANDS		119	193	74
LARGE FRACTURED GRAVELS	XXX	193	220	27

RECEIVED 2005 OCT 13 AM 11:04 STATE ENGINEERS OFFICE

UTM E 0267010
N 4307538
NAD 27 LC 12-19-05

Date started 9/12, 20 05
Date completed 9/14, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr 21	4.06	.216	20	220

Perforations:
Type perforation SAW SLOT
Size perforation 3 X 3/32
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55' ☒ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 220 feet

9. WATER LEVEL

Static water level 75 feet below land surface
Artesian flow G.P.M 30 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 10/6/05