

4 wells

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 98446

Permit No. _____

Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28797

1. OWNER WESTWARD HO ADDRESS AT WELL LOCATION 2920 INDUSTRIAL ROAD, LAS VEGAS, NV 89109
 MAILING ADDRESS 2900 LAS VEGAS BLVD SO. LAS VEGAS, NV 89109

2. LOCATION NE 1/4 SW 1/4 Sec 09 T. 21 N. R. 61 E. CLARK County
 PERMIT NO. 162-09-303-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>TYPE II SILTY SAND w/ CLAY</u>		<u>0.0</u>	<u>2.5</u>	<u>2.5</u>
<u>Caliche</u>		<u>2.5</u>	<u>7.0</u>	<u>4.5</u>
<u>Brown Clay</u>		<u>7.0</u>	<u>11.0</u>	<u>4.0</u>
<u>SANDS + GRAVEL</u>		<u>11.00</u>	<u>16.0</u>	<u>5.0</u>
		<u>16.00</u>	<u>20.0</u>	<u>14.0</u>

8. WELL CONSTRUCTION
 Depth Drilled 30.0 Feet Depth Cased 30.0 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 0.0 Feet 30.0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40 RW</u>	<u>0.0</u>	<u>30.0</u>

Perforations:
 Type perforation MACHINE SLOTTED
 Size perforation 1.020
 From 15.0 feet to 30.0 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 2'

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 12.0 feet to 30.0 feet

Date started 8-2 2005
 Date completed 8-3 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 17.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.D.C. EXPLORATION + WELLS Contractor
 Address 570 CORINTHIAN LN, N LAS VEGAS, NV, 89030 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-22-05