WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98470
Permit No.
Basin 104

NOTICE OF INTENT NO. 56386

1. OWNER Gary Readhead
MAILING ADDRESS 2555 Damon Way
Carson City, NV 89701

ADDRESS AT WELL LOCATION 2555 Damon Way Carson City, NV.

2. LOCATION ~~NW~~/NW 1/4 NE 1/4 Sec. 28 T 15N N/S R 20 ~~N~~E E Carson County
PERMIT NO. n/a Issued by Water Resources
Parcel No. 10-161-52
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 231' of 1-1/4" drop pipe and pump. Measured static water level at 203' and the depth of the 6" well at 245'. Original depth of well was 247'. Installed 6" Mills Knife to 200' and perforated 4 rows per foot from 200' to 160'. We then attempted to perforate from 50' back to surface but there was a concrete seal around the casing. We then installed 241' of 2" tremme pipe for grouting. We mixed 72 bags of Portland Type II cement with approximately 375 gallons of water and pumped the well full of neat cement from bottom to surface. (original log attached)				

RECEIVED 05 JUL 29 AM 11:35 WATER RESOURCES OFFICE

Date started 7/21/2005, 19__
Date completed 7/21/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188"	+2	245'

Perforations:
Type perforation Slotted and Mills Knife
Size perforation
From 160' feet to 247' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 245'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 203' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 1482
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 39920
Signed Dan Trampe (By driller performing actual drilling on-site or contractor)
Date 7/28/2005

USE ADDITIONAL SHEETS IF NECESSARY