

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 98479
 Permit No. _____
 Basin 105
 NOTICE OF INTENT NO. 52328



Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

1. OWNER PAUL VANOS
 MAILING ADDRESS 1693 HYDE ST
MINDEN, NV 89423
 ADDRESS AT WELL LOCATION 1693 HYDE ST
MINDEN, NV 89423

2. LOCATION SE NW 1/4 NE 11/4 Sec 2 T 13 N R 20 E DOUGLAS County
 PERMIT NO. DOM-05-019 1320-02-001-115

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	20	20
MED GRAVELS				
BROWN CLAY		20	150	130
BROWN CLAY & DG SANDS	X	150	240	90
BLUE GRAY CLAY		240	322	82
GRAY CLAY & DG		322	345	23
GUMMY GRAY CLAY		345	356	11
MALL DG SANDS AND CLAY BALLS	XXX	356	390	34

8. WELL CONSTRUCTION
 Depth Drilled 390' Feet Depth Cased 390' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 390 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	13.03	.188	+2	390

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3X 3/32
 From 300 feet to 340 feet
 From 360 feet to 380 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 390 feet

9. WATER LEVEL
 Static water level 163' feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 8/3, 20 05
 Date completed 8/8, 20 05

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>110</u>	<u>3 HRS</u>

Name CAPITAL CITY WELL DRILLING
 (CONTRACTOR)
 Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 0055548
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
 Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 8/11/05