WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98911
Permit No.
Basin 212

NOTICE OF INTENT NO. 2956

1. OWNER WILLIAM LYON HOMES INC ADDRESS AT WELL LOCATION 5080 Gold Field ST, NLV. NV.
MAILING ADDRESS

2. LOCATION NE ¼ SE ¼ Sec. 34 T. 19 S N/S R. 61 E. CLARK County
PERMIT NO. Issued by Water Resources 124-34-701-025 Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDON A 8 5/8 Steel Well				
Depth: 300 Ft.				
Pull Pump				
Drill out Debris: Wood + Rock				
Perforate From Bottom up To 50 ft.				
Air Perforator - 4 Times Around				
Cement From Bottom up To 20 ft				
Neat Cement 27 Sack Mix.				
Cement From 20 To Surface with				
5½ Sack 3/4 Rock Cement.				
Static Water 87 ft.				

PLUGGED BY GWMP
ORIG PLUG LOG # 60709

RECEIVED
MAR 0 5 2006
LAS VEGAS OFFICE

Date started 1-10-06, 19
Date completed 03-08-06, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Vernon H. Dimick
Address (Contractor) 5360 N. Bonita Vista St.
LAS VEGAS, NEV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
(By driller performing actual drilling on site or contractor)
Date 03-08-06

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (01-622)