WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98912
Permit No.
Basin 212

NOTICE OF INTENT NO. 29508

1. OWNER WILLIAM LYON HOMES INC
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5 E LONE MOUNTAIN NLV, NEV

2. LOCATION NE ¼ NE ¼ Sec. 3 T. 20 S N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) 139-03-503-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDON 8 5/8 STEEL CASED WELL				
DEPTH: 200 FT.				
PULL PUMP				
NO DEBRIS				
PERFERATE FROM BOTTOM UP WITH				
AIR OPERATED PERFERATOR 4 TIMES				
AROUND UP TO 50 FT.				
CEMENT FROM BOTTOM UP WITH				
27 SACK NEAT CEMENT UP TO 10 FT.				
CEMENT FROM 10 ft TO SURFACE				
WITH 5½ SACK 3/4 ROCK CEMENT				
STATIC WATER 49 ft.				

DCNR/DWR
RECEIVED
MAR 0 9 2006
LAS VEGAS OFFICE

Date started 1-10-06, 20
Date completed 03-08-06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON H. DIMICK
Contractor
Address 5360 N. BONITA VISTA ST.
Contractor
LAS VEGAS, NEV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on site driller 552
Signed V. H. Dimick
By driller performing actual drilling on site or contractor
Date 03-08-06

(Rev. 12-01)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627