COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99006
Permit No.
Basin 212

NOTICE OF INTENT NO. 29754

1. OWNER CRESENT REAL ESTATE EQUITIES
MAILING ADDRESS 777 Main Street #2100
Fort Worth, TX 76102-5366

ADDRESS AT WELL LOCATION 3883 Howard Hughes Pkwy
Las Vegas, NV

2. LOCATION SE ¼ SE ¼ Sec 16 T 21 S R 61 E CLARK County

PERMIT NO. DW1211 (Issued by Water Resources) | 162-16-812-004 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 6-Dewatering wells | | | | |
| Silty Clay | | 0 | 2 | |
| Caliche | | 2 | 5 | |
| Brown Clay | | 5 | 22 | |
| Caliche | | 22 | 24 | |
| White clay | | 24 | 30 | |

DCNR/DWR
RECEIVED
MAR 23 2006
LAS VEGAS OFFICE

Date started 2/28, 20 06
Date completed 3/3, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | 1.250 | 0 | 30 |

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5"x3 rows @13
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 2' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 West Tompkins Ave. (CONTRACTOR)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2231
Signed [signature]
By driller performing actual drilling on site or contractor
Date 3/21/06


Forms Provided by Forms-On-A-Disk, Inc. • (214) 340-9429 • FormsOnADisk.com