WASHOE # WL50211

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 99067
Permit No.
Basin 081

NOTICE OF INTENT NO 55079

1. OWNER **Aqua Traac LLC**
MAILING ADDRESS **5405 Mae Anne Ave**
Reno, NV 89523

ADDRESS AT WELL LOCATION **WL-1A**

2. Location **NE** 1/4 **NW** 1/4 Sec **30** T **24** N R **24E** **Washoe** County
PERMIT NO. MO1384 PARCEL N0. **079-310-75** SUBDIVISION NAME

3. WORK PERFORMED
X New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE
Domestic | Irrigation | X Test
Municipal/Industrial | X Monitor | Stock

5. WELL TYPE
Cable | X Rotary | RVC
Air | Other | X Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel.		**0**	**27**	**27**
				0
Clay & gravel..		**27**	**52**	**25**
				0
Clay & 1/4" gravel.		**52**	**87**	**35**
				0
Gravel-clay.		**87**	**137**	**50**
				0
Gravel & rock.		**137**	**183**	**46**
				0
Clay & cobbles.		**183**	**201**	**18**
				0
Gravel clay.		**201**	**345**	**144**
				0
Gray clay.		**345**	**363**	**18**
				0
Rock.		**363**	**382**	**19**
				0
Clay.		**382**	**387**	**5**
				0
Gravel & clay.		**387**	**520**	**133**
				0
				0
				0
				0
				0
				0
				0
				0

Date started **9-15** -05
Date completed **10-3** -05

7. WELL TEST DATA
TEST METHOD; Bailer Pump x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
75	380	
100	**430**	

8. WELL CONSTRUCTION
Depth Drilled **520** feet Depth Cased **520** feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	inches	**0** feet	**520** feet
	inches	feet	feet
	inches	feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
8 5/8	**16.94**	**.188**	**&2**	**520**

Perforations::
Type Perforation **Factory**
Size perforation **screen**
From **125** feet to **155** feet
From **170** feet to **190** feet
From **200** feet to **205** feet
From **390** feet to **400** feet
From 450 feet to **510** feet

Surface Seal X YES No
Depth of Seal **100** feet
x Pumped
Poured
Gravel Packed: x Yes No
From **100** feet to **520** feet

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

9 WATER LEVEL
Static water leve**70** feet below land surface
Artesian flow **0** GPM **0** P.S.I.
Water Temperature **cold** Degrees F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 10-18 -05