



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56759

1. OWNER George Kirka ADDRESS AT WELL LOCATION 1533 ALBA VISTA
 MAILING ADDRESS _____
 2. LOCATION NB 1/4 SW 1/4 Sec. 17 T. 10 N/S R. 22 E. Douglas County
 PERMIT NO. 1022-17002-020 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-GRAVEL		0	14	14
COBBLES		14	22	8
BROWN CLAY-GRAVEL		22	100	78
BOWLDER		100	103	3
BROWN CLAY-GRAVEL		103	140	37
BROWN STICKY CLAY		140	144	4
BROWN CLAY-GRAVEL		144	165	21
LARGE GRAVEL		165	195	30
MEDIUM GRAVEL-CLAY		195	215	20

8. WELL CONSTRUCTION
 Depth Drilled 215 Feet Depth Cased 215 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches 0 Feet 75 Feet
 To 9 7/8 Inches 75 Feet 215 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>1</u>	<u>215</u>
5 7/8	11	.188		

 Perforations: FACTORY MILLED
 Type perforation ~~STAINLESS STEEL~~
 Size perforation ~~1 1/2" x 3"~~ 3/32" x 3"
 From _____ feet to _____ feet
 From 135 feet to 215 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 54 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 215 feet
 9. WATER LEVEL
 Static water level 81 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

Date started 11 JAN 06, 20____
 Date completed 19 JAN 06, 20____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18-20</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address PO Box 1255
Carson City, NV 89702
 Nevada contractor's license number 46498
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2167
 Division of Water Resources, the on-site driller
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 19 JAN 06