WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99089
Permit No.
Basin 088

NOTICE OF INTENT NO. 56592

1. OWNER Larry Myers
MAILING ADDRESS 5350 Cedarwood Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 5350 Cedarwood Dr.

2. LOCATION NE NW 1/4 NW NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County

PERMIT NO. Dom05-029 (Issued by Water Resources) 045-573-15 (Parcel No.) Subdivision Name

3. **WORK PERFORMED**
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [x] Deepen
- [ ] Abandon
- [ ] Other

4. **PROPOSED USE**
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. **WELL TYPE**
- [ ] Cable
- [x] Rotary
- [ ] RVC
- [ ] Air
- [x] Other Mud

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Sand cobbles		120	160	40
Sand cobbles clay				
brown		160	180	20
Sand cobbles		180	200	20
Sand cobbles rock		200	230	30
Sand brown clay		230	240	10
Sand cobbles		240	260	20
Sandy brown clay		260	265	5
Sand cobbles		265	280	15
Sandy clay cobbles		280	300	20
Sand cobbles	X	300	340	40

Washoe County Well Permit # WL050298

Date started 11/22/2005, 19__
Date completed 11/25/2005, 19__

7. **WELL TEST DATA**

TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3

8. **WELL CONSTRUCTION**

Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	120	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	110	340

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

From 300 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. **WATER LEVEL**
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/1/2005

USE ADDITIONAL SHEETS IF NECESSARY