

Log No. 99109
 Permit No. _____
 Basin 053

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28683

1. OWNER Teck Cominco American, Inc. ADDRESS AT WELL LOCATION APPROX 40 mi. Northwest of Eureka Nevada
 MAILING ADDRESS 15918 E Euclid Ave. Spokane Wa. 99216
 2. LOCATIONS SW 1/4 SW 1/4 Sec. 32 T. 27 N. R. 49 E. Eureka County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Attempted to pull casing but it was sealed in with neat cement</u>				
<u>Ran Tremie to bottom and filled well to surface with neat cement</u>				
<u>Hand Held GPS</u>				
<u>N 40° 10.400'</u>				
<u>W 116° 28.883'</u>				

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>+2</u>	<u>50</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

BMW-24
 Date started Oct. 24, 2005
 Date completed Oct. 24, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Layne Christensen Company
 Address 4490 West 1707 South Salt Lake City Utah 84104
 Nevada contractor's license number issued by the State Contractor's Board 0019101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1970
 Signed William L. Franklin
 By driller performing actual drilling on site or contractor
 Date Nov. 16, 2005