


REPORT NO. **A05.107**

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



LOG NO. 99162
PERMIT NO. _____
BASIN Ø83

NOTICE OF INTENT NO. **55410**

1. OWNER **Brian & Giana Edberg**
MAILING ADDRESS **1320 Yellowjacket Rd. VC Highlands, NV**
2. WELL LOCATION **NW 1/4 SW 1/4 SEC. 30 T 18N R 21 E Storey** COUNTY
PERMIT NO. _____ PARCEL NO. **03-321-37** SUBDIVISION NAME _____

ADDRESS OF WELL **1320 Yellowjacket Rd. Virginia City Highlands, NV 89521**

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Yellow/white/rust soft rock		0	5	5
Gray clay		5	15	10
Dark blue w/ white specks		15	17	2
Blue/green hard VR & brown clay		17	30	13
Green/yellow/rust VR some clay		30	40	10
Blue/green hard VR		40	47	7
Yellow/rust softer rock no clay		47	55	8
Blue & green VR		55	63	8
Rust & maroon VR, some gray clay		63	90	27
Multi color VR specks gray clay		90	110	20
Yellow & rust rock		110	160	50
Mixed yellow/rust/tan VR		160	310	150
Multi blue/gray harder VR		310	370	60
All blue hard VR some fractures		370	390	20
Fractured dk blue w/ white specks	X	390	438	48

8. WELL CONSTRUCTION

Depth Drilled **438** Depth Cased **438**

HOLE DIAMETER (BIT SIZE)

10 Inches **0** Feet **50** Feet
8 Inches **50** Feet **438** Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2.5	438

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 x 3**
From **398** Feet to **438** Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL:

Yes No SEAL TYPE:
 Neat Cement
Seal Depth **50** Cement Grout

PLACEMENT METHOD:

Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED:

Yes No
From **50** Feet to **438** Feet

9. WATER LEVEL

Static Water Level **342** Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature **cool** F Quality **clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**
Address **675 Edison Way Reno, NV 89502**

NV. CONTRACTOR'S LIC. NO. **15291** DRILLER'S LIC. NO. **2189**
ON SITE

Signed *Roger M. Thull*
By driller performing actual drilling on site or contractor

Dated **November 15, 2005**

Notes : Latitude: **N39 degrees 23.760'**
Longitude: **W119 degrees 40.533'**

Date Started **11/8/05** Date Completed **11/15/05**

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

GPM	DRAWDOWN	TIME (HRS)
20+		1 hour

RECEIVED
2005 DEC - 15 AM 11:30
STATE ENGINEERS