WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99207
Permit No.
Basin 067

NOTICE OF INTENT NO. 56395

1. OWNER Dan Dragan
MAILING ADDRESS 6210 Valley Wood Drive
Reno, NV

ADDRESS AT WELL LOCATION 150 Thomas Ave., Reno, NV.

2. LOCATION NE 1/4 SE 1/4 Sec. 13 T 19N N/S R 18E E Washoe County
PERMIT NO. _____ Issued by Water Resources | 039-148-13 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Mobilized to site and removed 140' of 1-1/4" drop pipe and pump. Measured static water level at [redacted]51' and depth of well at 152'. Installed Mills Knife and perforated 4 rows per foot from 126' back to 50'. From 50' to surface there was some resistance when perforating so there was a sanitary seal. We installed 147' of 2" tremme pipe. We then mixed 75 bags of Portland Type II cement with 375 galons of water and pumped in neat cement from bottom of well to surface. (original log attached)				

RECEIVED
2005 DEC -1 AM 10: 52
STATE ENGINEER'S OFFICE

Date started 11/21/2005, 19__
Date completed 11/21/2005, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 152' Feet Depth Cased 150' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"		.188	150'	+1'

Perforations:
Type perforation Mills Knife
Size perforation
From 126' feet to 50' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 152'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. **WATER LEVEL**
Static water level [redacted]51' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Dragan (By driller performing actual drilling on-site or contractor)
Date 11/30/2005

USE ADDITIONAL SHEETS IF NECESSARY