WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99220
Permit No.
Basin 139

NOTICE OF INTENT NO. 28582

1. OWNER Atlas Corp
MAILING ADDRESS PO Box 292
Eureka NV 89316

ADDRESS AT WELL LOCATION 20 Miles North on 3 Bar road

2. LOCATION NE ¼ SW ¼ Sec. 35 T. 22 ☒S R. 50 E. Eureka County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
pw 3				
old intent #				
13524				
perforation				
50 - 400 ft				
4 rows				
with Holte air				
perforator				
pump Arbuckle				
grout 134 Bag				
42 Gallons of water				
per Bag 5628 Gallons				
pump 50 ft				
Neat grout in				
Hole 24 Bag				
Cement 100 LB				
cut of well				
-1 ft				
Below ground				

Date started 12-14-05, 20
Date completed 12-20-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased 1065 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	1065 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.36	250	+1	1065

Perforations:
Type perforation Mill slot
Size perforation 8 5/8 - double pack
From 399 feet to 1065 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 97 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 6 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 580 W Silver St (Contractor)
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed (By driller performing actual drilling on site or contractor)
Date 12-27-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627