WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99346
Permit No.
Basin Ø92A

NOTICE OF INTENT NO. 56912

1. OWNER Trammel Crow Construction
MAILING ADDRESS 6980 Sierra Center Parkway Ste 170 Reno, NV. 89511
ADDRESS AT WELL LOCATION ~~Enterprise~~ Industry Circle Sparks, NV,

2. LOCATION NE ¼ SE ¼ Sec. 30 T. 21 N S R. 19 E. Washoe County
PERMIT NO. D-001280 NDEP (Issued by Water Resources) | 090-40-05 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fill lt brown		0	7'	7'
silt lt brown		7'	13'	6
sand med brown		13'	30'	17'

contractor to grout main hole after final grading of site

Date started Nov 16, 20 05
Date completed Nov. 16, 20 05

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10.25 Inches		0 Feet	30' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	10'

Perforations:
Type perforation Factory Slot .020
Size perforation
From 10' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
* bem chips 0-8'
Gravel Packed: ☑ Yes ☐ No
From 8 feet to 30' feet

9. WATER LEVEL
Static water level 18.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 58.5° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hoz Tech Drilling (Contractor)
Address P.O 940 Gardnerville Nv 89460 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1803 T1
Signed (By driller performing actual drilling on site or contractor)
Date 12-3-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627