


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 99421
Permit No. _____
Basin 162



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29616

1. OWNER BRIAN O'LTMANN'S ADDRESS AT WELL LOCATION 1361 W GEOFREY ST
MAILING ADDRESS 1361 W GEOFREY ST
PAHRUMP, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 32 T 19S N/S R 53E E NYE County
PERMIT NO. 41-573-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	64	64
CALICHE	WB	64	66	2
CLAY		66	94	28
CALICHE	WB	94	106	12
CLAY		106	132	26
CALICHE	WB	132	138	6
CLAY		138	166	28
CALICHE	WB	166	179	13
CLAY		179	200	21

DCNR/DWR
RECEIVED
MAY 1 2006
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches 0 Feet To 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From	feet to	feet
<u>140</u>		<u>200</u>

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor

Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 4/26/2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			