WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99475
Permit No.
Basin 042

NOTICE OF INTENT NO. 55265

1. OWNER: Pete Turner
MAILING ADDRESS: P.O. Box 723, WEIls, NV 89835
ADDRESS AT WELL LOCATION: Off U.S. 93 Bar HL Rd Parcel 2

2. LOCATION: NE 1/4 NW 1/4 Sec. 17 T 38 N/S R 63 E ELKO County
PERMIT NO. (Issued by Water Resources)
Parcel No. 008-570-011
Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Gravel mix		0	19	19
Cobbles		19	26	27
Brown Clay		26	78	52
Cobbles	X	78	82	4
Brown Clay		82	120	38
Cobbles/some water	X	120	121	1
Hard Rock		121	200	79

RECEIVED 2006 MAY -1 PM 1:20 STATE ENGINEER'S OFFICE

Date started: February 21, 2006, 19__
Date completed: April 10, 2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	7		Days

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	12
6	SDR-21		12	200

Perforations:
Type perforation: screen
Size perforation: .030
From 180 feet to 200 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No Bentonite 11-54
From 54 feet to 200 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature cold °F Quality ___

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Sharel C. Fertig Sr.dba Fertig Drill.
Address (Contractor): P.O. Box 525, Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board: 03904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1584
Signed (By driller performing actual drilling on-site or contractor): [signature]
Date: 4-21-06

USE ADDITIONAL SHEETS IF NECESSARY