WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99477
Permit No.
Basin 087

NOTICE OF INTENT NO. 57385

1. OWNER Richard & Terry Shannon
MAILING ADDRESS 5847A Carl Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 5847A Carl Dr.

2. LOCATION SE 1/4 SW 1/4 Sec. 26 T 18N N/S R 19E E Washoe County
PERMIT NO. _____ Issued by Water Resources
150-260-35 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" x 295' water well. We found a liner at 235'. We perforated at four around and at one foot intervals. We also perforated the top 50' of the well as we found no evidence of a sanitary seal. We then poured 3.5 cu. yards of neat cement mixed 5.2 gal/sack into the well. We cut the top 2' off of the casing.				
Washoe Co. Permit #WL060036				

RECEIVED 2006 MAY -1 PM 1:04 STATE ENGINEER'S OFFICE

Date started 4/6/2006 , 19__
Date completed 4/19/2006 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	240?
5 9/16	10	.188	235	295

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 275' feet to 210' feet
From 50' feet to 0' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 292 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce Mackay
By driller performing actual drilling on-site or contractor
Date 4/19/2006

USE ADDITIONAL SHEETS IF NECESSARY