WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99486
Permit No.
Basin 058

NOTICE OF INTENT NO. 57281

1. OWNER Edward & Ramona Hintz
MAILING ADDRESS 272 Springfield Parkway
Spring Creel, NV 89815

ADDRESS AT WELL LOCATION 2383 Corral Lane, Lot 22

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 33N N/S R 56E E Elko County
PERMIT NO. Issued by Water Resources | 006-30C-022 Parcel No. | Area West Division of Lands Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary RVC
[X] Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soill		0	2	2
Sand & gravel		2	100	98
Hard clay		100	130	30
Gravel & soft gray		130		
clay			150	20
Soft tan clay		150	160	10
Gravel & clay	XX	160	170	10
Gravel	XX	170	205	35

Installed 20 bags of 3/8" medium chip bentonite from 50' to 10' and neat cement from 10' to the surface.

Date started 4/27/2006, 19__
Date completed 4/28/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1.5

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	205 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+2	205

Perforations:
Type perforation Slots
Size perforation 3/16x 3 6 rows
From 185 ~~180~~ feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50' to 205.
Placement Method: [ ] Pumped [X] Poured
Seal Type: X Neat Cement, Cement Grout, Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 205 feet

9. WATER LEVEL
Static water level 119 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC Contractor
Address P.O.BOX 850 Contractor
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166
Signed Dale C. Vedan
By driller performing actual drilling on-site or contractor
Date 5/2/2006

USE ADDITIONAL SHEETS IF NECESSARY