WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99487
Permit No.
Basin 043

NOTICE OF INTENT NO. 57282

1. OWNER Edgar & Olivia Cobain
MAILING ADDRESS P.O. Box 77
Deeth, NV 89823

ADDRESS AT WELL LOCATION Unknown

2. LOCATION SW 1/4 SE 1/4 Sec. 25 T 36N N/S R 59E E ELKO County
PERMIT NO. (Issued by Water Resources) 007-330--031 (Parcel No.) RURAL (Subdivision Name)

3. **WORK PERFORMED**
X New Well ☐ Replace ☐ Recondition
Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary RVC
☒ Air Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
SAND, GRAVEL, & ROCKS		1	60	59
FINE GRAVEL	X	60	70	10
GRAVEL w/CLAY		70	75	5
FINE GRAVEL	X	75	120	45

PLACED 44 BAGS OF 3/8 MEDIUM CHIP BENTONITE FROM 50' TO 10' & NEAT CEMENT FROM 10' TO THE SURFACE.

INSTALLED WELL CAP.

Date started 4/13/2006, 19__
Date completed 4/27/2006, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1

8. **WELL CONSTRUCTION**
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+2	120

Perforations:
Type perforation SLOTS
Size perforation 3/16X3 6 ROW
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. **WATER LEVEL**
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166
Signed Dale C. Veden
By driller performing actual drilling on-site or contractor
Date 4/28/2006

USE ADDITIONAL SHEETS IF NECESSARY