WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99536
Permit No.
Basin 107

NOTICE OF INTENT NO. 54271

1. OWNER DA Development
MAILING ADDRESS
ADDRESS AT WELL LOCATION 181 Bucks Court

2. LOCATION ~~NE~~ ¼ NE ¼ Sec. 27 T. 11 N/S R. 23 E. Lyon Co County
PERMIT NO. (Issued by Water Resources) 009-251-01 (Parcel No.) Smith Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Silt		0	15	15
D G Granite	✓	15	170'	155
Sand & Gravel Silt Dirty Water Will Not Clean up.	✓	170	250	80
Clay Gray		250	260	10'
Sand & Gravel	✓	260	312	52

Date started Dec 15/05, 20
Date complated Jan 3/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15 Gpm		2 Hrs	

8. WELL CONSTRUCTION
Depth Drilled 312' Feet Depth Cased ~~313~~ 312' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	250' Feet
Inches	Feet	Feet
6" Inches	250 Feet	312' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.250	+1	20'
6 5/8	PVC	200 psi	20	250'
5"	Steel	.250	160	312'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3"
From 230 feet to 250 feet
From feet to feet
From 292 feet to 312' feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 250' feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address PO Box 579 Contractor
[signature] NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date Jan 31/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627