COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99600
Permit No.
Basin 101

NOTICE OF INTENT NO. 56664

1. OWNER CASEY PROPERTIES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1979 HILLSBORO
~~4240 RENO HWY~~
FALLON, NV 89406

2. LOCATION ~~SE~~ ¼ ~~NW~~ ¼ Sec 22 T 19 N R 28 E CHURCHIL County
PERMIT NO. SW NE (Issued by Water Resources) | 008-231-34 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL			1	1
BROWN SAND		1	12	11
BROWN CLAY		12	15	3
BROWN SAND		15	30	15
BROWN CLAY		30	40	10
GRAY SANDS		40	75	35
BLACK SILT/CLAYS		75	100	25
GRAY SANDS		100	140	40
GRAY CLAY		140	150	10
GRAY SANDS		150	155	5
GRAY CLAY		155	160	5
BROWN SANDS	X	160	171	11

RECEIVED 2006 APR 11 AM 11:18 STATE ENGINEER'S OFFICE

Date started FEBRUARY 22, 20 06
Date completed MARCH 10, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION

Depth Drilled 171 Feet Depth Cased 171 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	171 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	171

Perforations:
Type perforation MACHINE SLIT
Size perforation .088
From 164 feet to 168 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From feet to feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

9. WATER LEVEL
Static water level 23'6" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date APRIL 07, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com