COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99601
Permit No.
Basin 101

NOTICE OF INTENT NO. 56679

1. OWNER MARK KOLWYK
MAILING ADDRESS 5140 RAN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5140 ORAN ROAD
FALLON, NV 89406

2. LOCATION SE ¼ SE ¼ Sec 8 T 18 N R 28 E CHURCHILL County

PERMIT NO. | Issued by Water Resources | 006-292-96 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	17	16
BROWN CLAY		17	20	2
BROWN SILT		20	35	15
BROWN CLAY		35	40	5
GRAY SANDS		40	80	40
GRAY CLAY		80	90	10
GRAY SANDS/GRAVEL		90	120	30
GRAY CLAY		120	135	15
GRAY SANDS		135	150	15
GRAY CLAY		150	152	2
BROWN SANDS	X	152	160	8

RECEIVED APR 11 AM 11:18 2006 STATE ENGINEER'S OFFICE

Date started JANUARY 28, 20 06
Date completed MARCH 10, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	160

Perforations:
Type perforation MACHINE SLIT
Size perforation .088
From 154 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 24'6" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date APRIL 7,2006