WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99608
Permit No.
Basin 212

NOTICE OF INTENT NO. 29514

1. OWNER QHNV, LLC (EVAN SLAWSON)
MAILING ADDRESS 2349-A RENAISSANCE DR. LV. NV. 89119
ADDRESS AT WELL LOCATION 2035 MORENO Rd. LV. NV. 89124

2. LOCATION NW ¼ SE ¼ Sec. 6 T. 21 S N/S R. 59 E. CLARK County
PERMIT NO. (Issued by Water Resources) 164-06-701-004 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
White Rock		3	12	
Reddish Sandstone		12	95	
Hard Limestone		95	100	
Reddish Sandstone		100	165	
Red Shale		165	345	
Hard White Sandstone	X	345	540	
Reddish Sandstone		540	570	
Red Shale		570	750	
Limestone + Water	X	750	785	
Green Shale		785	795	

DCNR/DWR
RECEIVED
JUN 09 2006
LAS VEGAS OFFICE

Date started 05-19-06, 19
Date completed 06-01-06, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 795 Feet Depth Cased 795 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	50 Feet
8¾ Inches		50 Feet	795 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	+2	5
6½	PVC	480	+1	795

Perforations:
Type perforation Drilled Holes
Size perforation ⅜" 4 Times Around
From 755 feet to 795 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 500 Ft.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 285 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON H. DIMICK (Contractor)
Address 5360 N. BONITA VISTA ST. (Contractor)
LAS VEGAS, NEVADA 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed VH Dimick (By driller performing actual drilling on site or contractor)
Date 06-02-06

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627