WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99643
Permit No.
Basin 207

NOTICE OF INTENT NO. 56041

1. OWNER David Petersen
MAILING ADDRESS Po Box 133 Lund NV 89317
ADDRESS AT WELL LOCATION 27 North Preston Ave.

2. LOCATION SW ¼ SE ¼ Sec. 12 T. 12 N/S R. 61 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) 013-022-11 (Parcel No.) Preston township (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 1 | |
| Brown clay gravel | | 1 | 10 | |
| green clay gravel | | 10 | 20 | |
| Red-Brown clay | | 20 | 55 | |
| Brown clay gravel | | 55 | 77 | |
| gravel | water | 77 | 80 | |
| gravel | water | 80 | 82 | |
| Brown clay | | 82 | 90 | |
| gravel | water | 90 | 91.5 | |
| Clay brown | | 91.5 | 95 | |
| clay green | | 95 | 100 | |
| gravel | water | 100 | 101 | |
| Clay | | 101 | 120 | |
| gravel | water | 120 | 121 | |
| Clay | | 121 | 129.5 | |
| gravel | | 129.5 | 130 | |

Date started March 30, 19 2006
Date completed March 22 2006

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 40 | 1 hr |

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 50 Feet |
| 8 Inches | | 50 Feet | 130 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 129 | .188 | -1 | 10 |
| 6 | | Sch 40 pvc | 10 | 130 |
| | | | | |

Perforations:
Type perforation mill
Size perforation .032
From 90 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 47226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed (By driller performing actual drilling on site or contractor)
Date March 28-06

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627