

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 99649  
 Permit No. \_\_\_\_\_  
 Basin 094

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57232

1. OWNER Robert Reaney  
 MAILING ADDRESS 4073 Snowshoe Ln  
Reno, NV 89506  
 ADDRESS AT WELL LOCATION 2540  
Benner/Dixie  
Rancho haven, NV.

2. LOCATION SW 1/4 SW 1/4 Sec 30 T 24 N R 19 E Washoe County

PERMIT NO. N/A 078-351-06  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Redish Sand		0	8	8
Red Clay		8	9	1
Red Sand		9	24	15
Red Rock		24	43	19
Red Clay		43	46	3
Red Rock	x	46	95	49
White Clay		95	97	2
Green Rock		97	124	27
White Clay		124	125	1
Green Rock		125	143	18
Red Rock		143	166	23
Gray Rock		166	195	29
Black Rock		195	260	65
Green Rock		260	305	45
Red Rock	x	305	326	21
Red Clay		326	330	4
Gray Rock		330	370	40
Red Rock		370	405	35
Green Rock		405	525	120
Green/Tan Rock	xx	525	565	40

8. WELL CONSTRUCTION  
 Depth Drilled 565 Feet Depth Cased 565 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 19 Feet  
9 7/8 Inches 19 Feet 565 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8" steel	14	.188"	-2	6
6 5/8" PVC	4.95	SDR 17	6	565

Perforations:  
 Type perforation Mill Slot  
 Size perforation .032  
 From 530 feet to 565 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 66'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 66 feet to 565 feet

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Artesian flow none G.P.M. none P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MILLER & SONS DRILLING CO.  
 (CONTRACTOR)

Date started 02-01, 20 06  
 Date completed 03-07, 20 06

7. WELL TEST DATE

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Approx (air)	30	280'	2
Pump	30	152'	12

Address P.O. Box 8056  
 (CONTRACTOR)  
Reno, NV 89507  
 Nevada contractor's license number issued by the State Contractor's Board 037915  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418  
 Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date 3-19-06