

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 455 RANCHO TTD ST

1. OWNER DAVID MATZEN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 455 RANCHO TTD ST, BATTLE MTN  
 2. LOCATION SW 1/4 SW 1/4 Sec. 24 T. 32 N/S R. 44 E. Lander County  
 PERMIT NO. 11-040-12 Parcel No. \_\_\_\_\_ Subdivision Name UNK  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
SAND + GRAVEL		5	20	15
TAN CLAY		20	40	20
BLUE CLAY		40	65	25
BLACK CLAY		65	75	10
TAN CLAY		75	90	15
Gravel	YRS	90	97	7
TAN CLAY	YRS	97	103	6
TAN CLAY	YRS	103	120	17

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 0 Feet To 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>71</u>	<u>120</u>

Perforations:  
 Type perforation Sanded  
 Size perforation 3/16 x 3  
 From 90 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 120 feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 6-1, 2006  
 Date completed 6-2, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>UNK</u>	<u>1 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name L. B. J. Drilling Co. Contractor  
 Address P.O. Box 902 Contractor  
W M C A 89446  
 Nevada contractor's license number issued by the State Contractor's Board 9605  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807  
 Signed Jacob  
 By driller performing actual drilling on site or contractor  
 Date 6-10-06