WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99693
Permit No.
Basin 066

NOTICE OF INTENT NO. 56881

1. OWNER Newmont mining Corp
MAILING ADDRESS P.O. Box 388 Valmy, NV 89438
ADDRESS AT WELL LOCATION Twin Creeks mine North of Golconda, NV

2. LOCATION SE ¼ NW ¼ Sec. 8 T. 39 N/S R. 43 E. Humboldt County
PERMIT NO. M/G-1403 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other PWA

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. M/O 8-5B LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	345	345
Competent Rock		345	680	
H2O Encounters		680 - 890'		
Place gravel in hole from 900' to 650				
Place Bentonite Seal in hole from 650' to 50'				
Cement Sanitary Seal from 50' to ground level.				
Develop well with Air ~~water~~				
Run Draw Down tests				
weld monument on well.				
and Set Cap.				
PLUGGED BY				
NDWR Well Log				
No. 113691				

Date started 4/19, 2006
Date completed 4/27, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 897 Feet

HOLE DIAMETER (BIT SIZE)

		From		To
8 3/4 Inches	0 Feet		560 Feet	
8 1/4 Inches	560 Feet		900 Feet	
Inches	Feet		Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/2		1/4	+3	-897

Perforations:
Type perforation Slot
Size perforation 1/8
From 657 feet to 857 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 650 feet to 900 feet

9. WATER LEVEL
Static water level 479' feet below land surface
Artesian flow no G.P.M. — P.S.I.
Water temperature — °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elklund Drilling Co Contractor
Address P.O. Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
Signed D.S.C. By driller performing actual drilling on site or contractor
Date 4/27/06

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627