COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99808
Permit No.
Basin 221

NOTICE OF INTENT NO. 23563

1. OWNER LINCOLN COUNTY WATER DIST. TPW-3
MAILING ADDRESS 704 WEST NYE, SUITE 201
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION TULE DESERT,
LINCOLN COUNTY, NV.
GPS:

2. LOCATION SW ¼ NW ¼ Sec 2 T 9 N R 69 E LINCOLN County

PERMIT NO. N/A (Issued by Water Resources) | N/A (APN) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL-CLAY		0	1050	1050
SANDSTONE		1050	1260	210
LIMESTONE		1260	1300	40
BEDDED SILTSTONE		1300	1950	650
LIMESTONE		1950	2025	75
SILTSTONE		2025	2080	55
QUARTZITE		2080	2105	125
LIMESTONE		2105	2265	160
SILTSTONE		2265	2290	25

DCNR/DWR
RECEIVED
JUN 12 2006
LAS VEGAS OFFICE

Date started 01-31, 20 06
Date completed 03-23, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
67		90

8. WELL CONSTRUCTION

Depth Drilled 2290 Feet Depth Cased 2264 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
31 Inches	0 Feet	77 Feet
22 Inches	77 Feet	2290 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	125.16	0.500	0	77
16	52.27	0.312	+2	2264

Perforations:
Type perforation LOUVERED
Size perforation 0.125"
From 1980 feet to 2050 feet
From 2080 feet to 2260 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 1953' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No ☐ 30% Grout
From 1953 feet to 2290 feet

9. WATER LEVEL
Static water level 1002' STILL RECOVERING feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (CONTRACTOR)
Address P.O. BOX 5279 (CONTRACTOR)
ELKO, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1366
Signed
By driller performing actual drilling on site or contractor
Date 03-28-06

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com