

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 99827  
 Permit No. \_\_\_\_\_  
 Basin 071  
 NOTICE OF INTENT NO. 55644

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Doug & Danne Crawford ADDRESS AT WELL LOCATION 7250 Jackson Road  
 MAILING ADDRESS PO Box 2096 Winnemucca, NV 89445  
Winnemucca, NV 89446

2. LOCATION NW 1/4 NE 1/4 Sec 13 T 35 N R 37 E Humboldt County  
 PERMIT NO. 013-541-27  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Rock		120	125	5
Gravel & Cobles		125	145	20
Rock		145	150	5
Sand & Gravel	X	150	170	20
Hard Rock		170	175	5
Lost 5 ft. hole when setting casing caved in w/ cobles.				

8. WELL CONSTRUCTION  
 Depth Drilled 175 Feet Depth Cased 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6.25 Inches To 120 Feet  
175 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5"</u>	<u>8</u>	<u>188</u>	<u>110</u>	<u>170</u>

Perforations:  
 Type perforation Factory cut  
 Size perforation 3/32x4  
 From 150 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal Existing  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 108 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cool °F Quality Good

Date started February 5, 20 06  
 Date completed February 6, 20 06

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>		<u>2</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fred Anderson & Sons Drilling, Inc.  
 (CONTRACTOR)  
 Address 10760 Grass Valley Road  
 (CONTRACTOR)  
Winnemucca, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date March 10, 2006