STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 99860
Permit No.
Basin 053

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57370

1. OWNER Tom Tomera
MAILING ADDRESS HC 65-11 Pine Valley--Stonehouse Ranch
Carlin, NV 89822

ADDRESS AT WELL LOCATION
Stonehouse Ranch, Pine Valley
Carlin, Nevada

2. LOCATION SW ¼ NW ¼ Sec 9 T 30N N/S R 52 E
PERMIT/WAIVER No. _____ Issued by Water Resources _____ Parcel No.

Latitude _____ UTM E _____ ☐ NAD 27
Longitude _____ N _____ ☐ NAD 83/WGS 84
Subdivision Name: _____ County: Lander

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	11	11
SAND		11	21	10
CLAY		21	68	47
BROWN ROCK		68	90	22
CLAY		90	95	5
GRAVEL		95	135	40
CLAY		135	140	5

Date started 16-Jan , 20 06
Date completed 19-Jan , 20 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/2	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+2	95

Perforations:
Type of perforation MILL SLOT
Size of perforation 0.09
From 95 feet to 135 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 47 FT feet below land surface
Artesian flow _____ G.P.M _____ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada, Inc., dba Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2099
Signed C. Jaynes - Office (By driller performing actual drilling on site or contractor)
Date 2/1/2006

(Rev. 12-05)

USE ADDITIONAL SHEETS IF NECESSARY