REPORT NO. A06.003

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 99898
PERMIT NO.
BASIN 102

NOTICE OF INTENT NO. 57091

1. OWNER Steve Gacho
MAILING ADDRESS P.O. Box 729 Mammoth Lakes, CA 93546

ADDRESS OF WELL Lot #4 The Narrows
Silver Springs, NV

2. WELL LOCATION NW 1/4 NW 1/4 SEC. 25 T 18N R 25 E Lyon COUNTY

PERMIT NO ____ PARCEL NO 015-281-49 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Red/brown clay, blue hard VR		0	22	22
Sands, hard blue VR		22	40	18
Fractured hard dark blue basalts		40	60	20
Hard black basalts, specks VR		60	95	35
Black basalts, specks red VR		95	110	15
Multi color VR, specks gray clay	x	110	200	90
Multi color VR & lots of black rock		200	220	20
Green/brown/red clay, small rock		220	225	5
Less clay, red VR		225	245	20
White & dark green clay		245	250	5
More rock & white clay		250	297	47

Notes: Latitude: N39 degrees 24.111'
Longitude: W119 degrees 8.189'

Date Started 1/12/06 Date Completed 1/18/06

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2 hours

8. WELL CONSTRUCTION

Depth Drilled 297 Depth Cased 297

HOLE DIAMETER (BIT SIZE)

10 Inches 0 Feet 100 Feet
8 1/2 Inches 100 Feet 297 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	297

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 177 Feet to 197 Feet
From 237 Feet to 297 Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 100
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 100 Feet to 297 Feet

9. WATER LEVEL
Static Water Level 158 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated January 18, 2006