(MW-7)

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99906
Permit No.
Basin 100A

NOTICE OF INTENT NO. 56916

1. OWNER Bordertown Casino
MAILING ADDRESS 19575 Hwy 395 North
Cold Springs NV 89506

ADDRESS AT WELL LOCATION 19555 Hwy 395 North
Cold Springs NV. 89506

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 21 ⊗/S R. 18 E. Churchill County
PERMIT NO. Facility ID # 4-000204 (APN) 840-140-16
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	6"
clay sand - red brown		6"	8'	7½'
sand - brown		8'	18'	10'
sand clay - brown		18'	28'	10'
clay - brown	↕ 44'	28'	60'	32'

Date started Mar 24, 20 06
Date completed Mar 24, 20 06

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60' Feet Depth Cased 60' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
810.25 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	60

Perforations:
Type perforation Factory Slot
Size perforation .020
From 40' feet to 60' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 38'
Placement Method: ☑ Pumped bentonite 33'-38' ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 38' feet to 60' feet

9. WATER LEVEL
Static water level 44' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling (Contractor)
Address P.O 940 Mudian Id 83650 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312
Signed (By driller performing actual drilling on site or contractor)
Date 4-26-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627