WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99920
Permit No.
Basin 107

NOTICE OF INTENT NO. 57386

1. OWNER B.D.R. Const.
MAILING ADDRESS P.O. Box 5086
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 32 Deer Pass Rd.

2. LOCATION NW 1/4 SW 1/4 Sec. 20 T 10N N/S R 24E E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 010-761-63 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silt | | 0 | 3 | 3 |
| Cobbles boulders sand | | | | |
| gravel | | 3 | 260 | 257 |
| Brown clay | | 260 | 270 | 10 |
| Cobbles sand gravel | | | | |
| some clay | X | 270 | 500 | 230 |

Date started 4/28/2006, 19__
Date completed 5/4/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | | 3 |

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 500 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 500 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

| | | | |
|---|---|---|---|
| From 320 | feet to | 340 | feet |
| From 360 | feet to | 380 | feet |
| From 400 | feet to | 420 | feet |
| From 440 | feet to | 460 | feet |
| From 480 | feet to | 500 | feet |

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 273 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/10/2006

USE ADDITIONAL SHEETS IF NECESSARY