



STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 99930  
 Permit No. \_\_\_\_\_  
 Basin. 207

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56043

1. OWNER Drock Sabaitis ADDRESS AT WELL LOCATION not assigned  
 MAILING ADDRESS po Box 68 Lund NV 89317  
 2. LOCATION NR 1/4 SE 1/4 Sec. 33 T 12 N/S R 62 E White Pine County  
 PERMIT NO. N/A 12-025-03 Lund town Plot Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy top soil		0	1	
Silt gravel cobbler		1	3	
Cemented gravel		3	18	
Clay gravel		18	23	
Cemented gravel		23	24	
Clay gravel		24	39	
gravel	water	39	40	
Sandy clay		40	50	
gravel		50	55	
Sandy clay		55	58	
gravel	water	58	60	
Sandy clay		60	67	
Clay		67	70	
gravel	water	70	71	
Sandy clay		71	73	
gravel	water	73	74	
Sandy clay		74	76	
gravel	water	76	80	
Sandy clay		80	85	
gravel	water	85	90	
Sandy clay		90	97	
gravel	water	97	102	
Sandy clay		102	105	
gravel		105	106	
Sandy clay		106	110	

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
~~8 Inches 75 Feet \_\_\_\_\_ Feet~~  
8 Inches 50 Feet 110 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.7</u>	<u>.188</u>	<u>-1</u>	<u>10</u>
<u>6</u>		<u>Sch. 40 PCL</u>	<u>10</u>	<u>110</u>

 Perforations:  
 Type perforation mill  
 Size perforation .032 x 6 row  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 70 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 110 feet

9. WATER LEVEL  
 Static water level 37.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Maynard Well Drilling Contractor  
 Address po Box 64 Lund NV 89317 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 47226  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed Maynard  
 By driller performing actual drilling on site or contractor  
 Date May 15-06

Date started April 24 2006  
 Date completed May 8 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>50</u>	<u>15.5</u>	<u>1.40</u>