WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99932
Permit No.
Basin 179

NOTICE OF INTENT NO. 51408

1. OWNER Rodney Riepenhoff
MAILING ADDRESS 251 Sunpac Avenue
Henderson, Nevada 89015
ADDRESS AT WELL LOCATION N. 21st West Street

2. LOCATION NE ¼ SE ¼ Sec 22 T 17 N/S R 63 E White Pine County
PERMIT NO. (Issued by Water Resources) 158 APN 5-591-45 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand & Course Gravel		3	15	12
Sand & Gravel		15	36	21
Clay		36	40	4
Sand & Gravel		40	50	10
Clay & Gravel		50	68	18
Water Sand & Gravel	X	68	75	7
Clay		75	85	10
Clay & Gravel		85	135	50
Water Sand & Gravel	X	135	145	10
Clay & Gravel		145	150	5
Clay		150	162	12

Date started April 24, 19 2006
Date completed April 27, 19 2006

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	92	2

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	162 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	162

Perforations:
Type perforation Factory
Size perforation 1/8" X 2½" 6 Rows
From 82 feet to 162 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 Feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 162 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date May 9, 2006

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627